



WANG LABORATORIES, INC.

ONE INDUSTRIAL AVENUE, LOWELL, MA 01851 • TEL: 617/459-5000, TWX 710-343-6769, TELEX 94-7421

The Sine Control International Corporation, transient surge suppressor, Model 120VF-2RP (PK+2), has been tested in our laboratory in accordance with the waveshape described in IEEE 587-1980, and the limits described in the Wang Standard for Power Line Impulse Suppressor Requirements, Revision 1 (draft), dated August 21, 1984.

As a result of this test program, we are pleased to inform you that this model, as tested, is fully compliant with all Wang specifications.